COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

		MO	DEL DAT	ΓA - F	OR (COMI	PRES	SED A	IR				
1	Manufacturer:	A1B20	C3, Inc.										
	Model Number: 1A2B 37kW								Dat	te:		09/10/18	
2	Air-cooled Water-cooled					,			Typ	oe:		Screw	
	Lubricated Oil Free					# O			of Stage	es:		1	
3*	Full Load Operating Pressure					12	25		psig b			psig	
4	Drive Motor Nominal Rating					5	0		hp				
5	Drive Motor Nominal Efficiency					94	.1		percent				
6	Fan Motor Nominal Rating (if applicable)					1	Į		hp				
7	Fan Motor Nominal Efficiency					82	.5		perce				
8*	Input Power			Ca	Capacity (acfm) ^{a,d}			Specific Power (kW/100 acfm) ^d					
	46.5				241				19.29				
	38.5					201			19.15				
	32.9					169			19.47				
	20.0					96			20.83				
	13.0					54			24.07				
9*	Total Package Input Power at Zero Flow c, d				0.0				kW				
10	Specific Power (kW/100 ACFM)		25 50 Note: Graph ote: Y-Axis Sca X		isual rep + 5kW/1	00acfm in	n of the d	if necessary		225	250	275	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.